

September 23, 2008

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: PUMP OR HOLDING
Model Number(s): 6000 LOW PROFILE
(70" L.L., 85.71 GAL/IN., 96" MAX. DEPTH OF BURY)
Product File No: 20080518

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.

This approval is valid until the end of NOVEMBER 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with an access opening above each inlet.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Low end and side pipe openings for pump, siphon and holding tanks.
 - Top inlet opening for holding, pump, or siphon tanks.
 - Six inch inlet and outlet openings.
 - ADS N-12 Prolink Pipe as a manhole riser and cover using an ADS coupler to join manhole riser sections together.
 - Zoeller Pump Co. Septic Tank Outlet Filter and Polylok Septic Tank Outlet Filter Model No. P1-122.
 - Inlet and/or outlet located along the side of the tank within 21 inches of the outside corner of the tank.

This approval supersedes the approval issued on 10/15/2007 under product file number 20070455. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070455.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov